

The following information is the City of Bolivar's results in regards to Ammonia as N and E.coli. The following dates are where permit limitations were exceeded.

Ammonia as N - Permit states limits shall not exceed 3.7 mg/L (Daily Limit) and 1.4mg/L (Monthly Limit) from April 1st to September 30th.

E.coli - Permit states limits shall not exceed a weekly average of 1030 MPN/100mL and a monthly average of 206 MPN/100 mL year-round.

Date	Ammonia as N (mg/L)	E.Coli (MPN/100mL)
April 9th	4.1 mg/L	
April Average	2.5 mg/L	
May 19th	4.9 mg/L	
May 28th	6.9 mg/L	2420 MPN/100mL
May Average	3.2 mg/L	
June 3rd	13 mg/L	2420 MPN/100mL
June 11th	7.5 mg/L	240 MPN/100mL
June 18th		2420 MPN/100mL
June 25th	7.2 mg/L	
June 30th	4.5 mg/L	
June Average	6.7 mg/L	
July 9th	4.4 mg/L	2420 MPN/100mL
July 15th	4.6 mg/L	2420 MPN/100mL
July 23rd	15 mg/L	2420 MPN/100mL
July Average	6.16 mg/L	1817.8 MPN/100mL
August 6th	4.9 mg/L	
August 13th	2.3 mg/L	
August Average	2.05 mg/L	

Ammonia as N - Permit states limits shall not exceed 8.1 mg/L (Daily Limit) and 3.1 mg/L (Monthly Limit) from October 1st to March 31st.

Date	Ammonia as N (mg/L)	E.Coli (MPN/100mL)
December 17th	9.8 mg/L	
December Average	5.8 mg/L	